



Product Service

Attestation of Conformity

No. N8A 098081 0022 Rev. 00

Holder of Attestation: **Jolywood (Taizhou) Solar Technology Co., Ltd.**
Kaiyang Rd.Jiangyan Economic Development Zone
225500 Taizhou City,Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062423204-00

Date, 2024-04-29

(Zhulin Zhang)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 098081 0022 Rev. 00

Model(s):

JW-HD156N-xxx, JW-HD156N-xxxS (xxx=610-635, in steps of 5)
 JW-HD144N-xxx, JW-HD144N-xxxS (xxx=545-590, in steps of 5)
 JW-HD108N-xxx, JW-HD108N-xxxS (xxx=415-445, in steps of 5)
 JW-HD156N-R0-xxx, JW-HD156N-R0-xxxS (xxx=610-645, in steps of 5)
 JW-HD144N-R0-xxx, JW-HD144N-R0-xxxS (xxx=570-595, in steps of 5)
 JW-HD108N-R0-xxx, JW-HD108N-R0-xxxS (xxx=420-450, in steps of 5)
 JW-HD120N-R3-xxx, JW-HD120N-R3-xxxS (xxx=480-515, in steps of 5)
 JW-HD108N-R3-xxx, JW-HD108N-R3-xxxS (xxx=430-460, in steps of 5)
 JW-HD144N-R1-xxx, JW-HD144N-R1-xxxS (xxx=595-625, in steps of 5)
 JW-HD120N-R1-xxx, JW-HD120N-R1-xxxS (xxx=495-525, in steps of 5)
 JW-HD108N-R1-xxx, JW-HD108N-R1-xxxS (xxx=445-470, in steps of 5)
 JW-HD132N-R2-xxx, JW-HD132N-R2-xxxS (xxx=595-625, in steps of 5)
 JW-HD120N-R2-xxx, JW-HD120N-R2-xxxS (xxx=540-570, in steps of 5)
 JW-HD108N-R2-xxx, JW-HD108N-R2-xxxS (xxx=485-515, in steps of 5)
 JW-HD96N-R2-xxx, JW-HD96N-R2-xxxS (xxx=430-460, in steps of 5)
 JW-HD132N-xxx, JW-HD132N-xxxS (xxx=685-715, in steps of 5)
 JW-HD120N-xxx, JW-HD120N-xxxS (xxx=625-655, in steps of 5)
 JW-HD156P-xxx, JW-HD156P-xxxS (xxx=580-605, in steps of 5)
 JW-HD144P-xxx, JW-HD144P-xxxS (xxx=525-555, in steps of 5)
 JW-HD108P-xxx, JW-HD108P-xxxS (xxx=395-415, in steps of 5)
 JW-HT156N-xxx, JW-HT156N-xxxS (xxx=610-635, in steps of 5)
 JW-HT144N-xxx, JW-HT144N-xxxS (xxx=545-590, in steps of 5)
 JW-HT108N-xxx, JW-HT108N-xxxS (xxx=415-445, in steps of 5)
 JW-HT156N-R0-xxx, JW-HT156N-R0-xxxS (xxx=615-645, in steps of 5)
 JW-HT144N-R0-xxx, JW-HT144N-R0-xxxS (xxx=570-600, in steps of 5)
 JW-HT108N-R0-xxx, JW-HT108N-R0-xxxS (xxx=420-450, in steps of 5)
 JW-HT120N-R3-xxx, JW-HT120N-R3-xxxS (xxx=480-510, in steps of 5)
 JW-HT108N-R3-xxx, JW-HT108N-R3-xxxS (xxx=430-460, in steps of 5)
 JW-HT144N-R1-xxx, JW-HT144N-R1-xxxS (xxx=595-625, in steps of 5)
 JW-HT120N-R1-xxx, JW-HT120N-R1-xxxS (xxx=495-520, in steps of 5)
 JW-HT108N-R1-xxx, JW-HT108N-R1-xxxS (xxx=445-470, in steps of 5)
 JW-HT132N-R2-xxx, JW-HT132N-R2-xxxS (xxx=595-625, in steps of 5)
 JW-HT120N-R2-xxx, JW-HT120N-R2-xxxS (xxx=540-570, in steps of 5)
 JW-HT108N-R2-xxx, JW-HT108N-R2-xxxS (xxx=485-515, in steps of 5)
 JW-HT96N-R2-xxx, JW-HT96N-R2-xxxS (xxx=430-455, in steps of 5)

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 098081 0022 Rev. 00

JW-HT156P-xxx, JW-HT156P-xxxS (xxx=580-605, in steps of 5)

JW-HT144P-xxx, JW-HT144P-xxxS (xxx=525-555, in steps of 5)

JW-HT108P-xxx, JW-HT108P-xxxS (xxx=395-415, in steps of 5)

xxx stands for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL 790
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China

Tested according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.